

Online Comment

Application H09-0523-20
Location Land off Damgate Holbeach Spalding
Proposal Details of Conditions 3, 4, 5, 6, 7, 8, 9, 10, 11, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22 and 23 H09-0332-16

Name Sue Armour
Address Environmental Protection Officer SHDC PE11 2XE

Date Submitted 05-08-20
For/Against Comments

I have reviewed the GeoDyne Limited report 'Dam Gate Holbeach Combined Phase I Desk Study and Phase II Exploratory Investigation' Project No: D38108 Date: 30th September 2019 and am in general agreement with the findings.

I therefore recommend discharge of parts i & ii of condition 3 of H09-0332-16, with parts iii & iv remaining outstanding.

The report recommends remediation and/ or further site investigation, and either option is acceptable.

The report currently recommends either installation of ground gas protection measures to CS2 or further monitoring to delineate the area of which these may be required. Either option is acceptable.

I look forward to receipt of a remediation method statement, containing detailed proposals for both items, in due course.