

Online Comment

Application H09-0748-20
Location HIGHFIELD FARM DAM GATE HOLBEACH PE12 8PB
Proposal Installation of pre-fabricated butchery unit into existing building

Name Steve Branson
Address South Holland District Council Priory Road

Date Submitted 09-10-20
For/Against Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5 dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.