H09/0807/96

27 AUG 1996

Form B (Type III)

Notes: This Form is for use in connection with an application for the Secretary of State for Energy's consent under **section 37** of the Electricity Act 1989 to install and keep installed above ground an electric line of a naminal voltage of less than 132 kilovolts. The Form should be sent **in triplicate** to each District/Borough Council in whose area the proposed development would be situated.

DETAILS OF APPLICANT
Name: East Midlands Electricity plc
Address: Tritton Road
Lincoln
Postcode: LN6 7RS
Telephone Number:

PART 1

East Midlands Electricity plc Application Number EM275/23/97952 Date 22 AUGUST 1996
To the Chief Executive Planning Department Council South Holland District

Dear Sir

Electricity Act 1989

Application is being made to the Secretary of State for Energy for his consent to the development described overleaf. The Secretary of State will at the same time be requested to direct that planning permission for this development shall be deemed to be granted. The consent and the direction may be given subject to conditions.

To assist the Secretary of State to determine the application the District/Borough Council is requested to return to me two copies of this Form with Part I Certificate and Part II completed and signed.

Department of the Environment Circular 14/90 (Welsh Office Circular 20/90)[Department of Energy Circular 1/90] describes this procedure and the reason for it.

Yours faithfully
For and on behalf of East Midlands Electricity plc.

Designation Project Manager

CERTIFICATE

(To be completed by or on behalf of the District/Borough Council)

The District/Borough Council
(i) object on the grounds set out below/have no objection to make to the development described overleaf.*
(ii) request/do not request that a public inquiry be held pursuant to paragraph 2 of Schedule 8 to the Electricity Act 1989 before the Secretary of State reaches his decision on the application.*

Date Signed

* Delete as appropriate Designation
On behalf of the District/Borough Council
(Reasons for objections)

East Midlands Electricity plc Application Number

(Application dated 22 August 1996)

PART II - INFORMATION AND OBSERVATION
(To be completed by the District/Borough Council)

Planning Reference Number EM275/23/97952

1. Names of interested parties consulted about the proposals with details of any observations received.

2. Particulars of any representations which have been made to the local planning authority objecting to the proposals.

3. Have any general or specific restrictions been imposed by any authority on development of the land affected by the proposed development?

PARTICULARS OF PROPOSED DEVELOPMENT AND REPRESENTATIONS
(To be completed by East Midlands Electricity plc)

Application is being made:

(a) for consent under section 37 of the Electricity Act 1989 to install or keep installed an electric line above ground;

(b) for a direction under section 90(2) of the Town and Country Planning Act 1990 that planning permission for the proposed development be deemed to be granted.

1. Particulars of proposed development. (These particulars should be accompanied by such plans as may be necessary to enable the local planning authority to identify the land affected by the proposals and to appreciate the nature and extent of the proposed development and by a copy of the environment statement if the applicant has prepared one.)

2. Particulars of any representations of objections which have been made to East Midlands Electricity plc.

   To erect the proposed 11000 volt overhead line on wooden poles in the parish of Holbeach St Marks with a tolerance of 30m either side of the route shown on the attached plan.

3. Particulars of the applicant's compliance with his duty under paragraph 1 of Schedule 9 to the Electricity Act 1989.

   To improve the reliability of electricity supplies in the Holbeach St Marks area EME plc are proposing to erect 360m of new 11kv overhead line along a farm roadway. Approximately 550m of low voltage overhead line is to be replaced by underground cable. 600m of high voltage line along the main Sluice Road will also be dismantled thereby removing a recognised traffic hazzard and improving the visual outlook. No trees, hedges or other natural features will be affected by this work.

Date 22 August 1996 For and on behalf of East Midlands Electricity plc

Signed Designation: Project Manager

Note: *This Part to be completed, dated and signed before submitting to the local planning authority*