

Online Comment

Application H09-0818-18
Location Northons Lane Holbeach PE12 7PZ
Proposal Details of boundary treatment/materials, contamination, management plan, refuse points, existing and proposed levels and surface water drainage (Conditions 5, 6, 8, 9, 10 and 16 of H09-0844-14)

Name Sue Armour
Address Environmental Protection Officer South Holland District Council

Date Submitted 06-12-18
For/Against Comments

I have reviewed the documents 'Interpretative Report on a Ground Investigation for a Proposed New Residential Development at Northons Lane, Holbeach' By Nicholls Colton Group report no. G16331-IR and the supplementary letter report dated 29/11/2018 regarding ground gas and I can confirm that this is sufficient to discharge parts i & ii of condition 6 of H09-0844-14.

The report recommends that ground gas protection measured in accordance with CS2 of BS8285:2015 are installed at this location, submission of the proposed design and installation details is required to discharge part iii.