Online Comment

Application	H09-0828-21
Location	BRITISH TELECOM TELEPHONE EXCHANGE BARRINGTON GATE PE12 7LB
Proposal	Proposed alterations to elevations of building to provide additional ventilation

---

Name	Steve Branson
Address	SHDC Priory Road
Date Submitted	23-08-21
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.