

Asher, Marie

From: Gedney, David
Sent: 27 March 2023 15:51
To: _planningadvice
Subject: AMENDMENT 2 - H09-0867-19 - Land off Balmoral Way, Holbeach
Attachments: Amendment Form.pdf

Amendment form. Plans previously sent through

Regards

David Gedney

Senior Planning Officer
South Holland District Council
T: 01775 764468
E: dgedney@sholland.gov.uk

Working Days: Monday, Tuesday & Thursday



Please note that any informal officer opinion expressed by this email is without prejudice and is not binding on the Council during the consideration of any formal application.

From: Gavin Baxter <gavin.baxter@ashwoodhomes.co>
Sent: 27 March 2023 14:48
To: Gedney, David <DGedney@sholland.gov.uk>
Cc: Adam Jagger <adam.jagger@ashwoodhomes.co>
Subject: FW: Ref. H09-0867-19 - Land off Balmoral Way, Holbeach

Mimecast Attachment Protection has deemed this file to be safe, but always exercise caution when opening files.

Caution: This message originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe. If you believe it is suspicious please forward to Suspicious.Emails@pspsl.co.uk and delete the email.

David

Resubmitted with Amendment Form as requested,

Kind Regards,

Gavin Baxter BSc(Hons)
Technical Manager

T: 01406 490590
M: 07538 180134
E: gavin.baxter@ashwoodhomes.co
W: www.ashwoodhomes.co

1 Goodison Road, Lincs Gateway Business Park,
Spalding, Lincolnshire PE12 6FY



From: Gavin Baxter
Sent: 27 March 2023 10:51
To: Gedney, David <DGedney@sholland.gov.uk>
Cc: Adam Jagger <adam.jagger@ashwoodhomes.co>
Subject: RE: Ref. H09-0867-19 - Land off Balmoral Way, Holbeach

David

Good morning,

We have compiled a full pack which may duplicate information previously submitted. Please refer to the attached letter which responds, in turn, to each comment raised by the EHO. We trust that the attached information and response is sufficient to enable them to sign off condition 4.

Kind Regards,

Gavin Baxter BSc(Hons)
Technical Manager

T: 01406 490590
M: 07538 180134
E: gavin.baxter@ashwoodhomes.co
W: www.ashwoodhomes.co

1 Goodison Road, Lincs Gateway Business Park,
Spalding, Lincolnshire PE12 6FY



From: Gedney, David <DGedney@sholland.gov.uk>
Sent: 20 March 2023 10:01
To: Gavin Baxter <gavin.baxter@ashwoodhomes.co>
Subject: Ref. H09-0867-19 - Land off Balmoral Way, Holbeach

Morning Gavin,

We have now received a reply from Environmental Protection concerning contamination (see below) and look forward to receipt of the information requested.

If you have any queries please contact Environmental Protection (email: pollution@sholland.gov.uk).

Regards

David Gedney

Senior Planning Officer

South Holland District Council

T: 01775 764468

E: dgedney@sholland.gov.uk

Working Days: Monday, Tuesday & Thursday



Please note that any informal officer opinion expressed by this email is without prejudice and is not binding on the Council during the consideration of any formal application.

From: planningadvice@sholland.gov.uk <planningadvice@sholland.gov.uk>

Sent: 20 March 2023 08:20

To: Gedney, David <DGedney@sholland.gov.uk>

Subject: Online web comments received for application: H09-0867-19

H09-0867-19

Comments have been received on the above application via the website and have been transferred to Ocella.

The comments are as follows:

Consultee Name: Jeanette Reith

Address: Environmental Protection - South Holland District Council

Date Transferred: Unrecognised Format

Planning Officer: Dave Gedney

Response Type: Comments

Comments:

Further to the Environmental Protection Team's previous comments I have reviewed the Supplementary Ground Gas Assessment by GeoDyne dated 24 February 2021. I note that Parts (i) and (ii) of Condition 4 of H09-0706-19 have already been satisfied by the Phase I & II reports by GeoDyne dated July 2015. As a remediation method statement (part (iii) of Condition 4 of H09-0706-19) has not been submitted for this site, the remediation proposals were never agreed prior to development taking place. I understand that the development is now complete. The Supplementary Ground Gas Assessment by GeoDyne deals solely with the ground gas protection requirements. GeoDyne have reassessed the original ground gas regime in their 2015 reports using subsequent, more recent guidance. They have also relied on third party verification (documentation from Ashwood Homes and Harlor) to evidence that the mitigation measures have been implemented. The report states that a 2000g dpm (Lingofol 500) membrane was installed in the properties, which is no longer generally accepted. However, they go on to say that 'where well installed and validated it should reduce the potential migration of ground gases from the subfloor void'. The report concludes that no further works or mitigation are necessary at the site with regards to ground gas. This supplementary report does not meet the verification requirements for gas protection measures as outlined in the technical guidance produced by YALPAG in 2016. For example, there are no plans or photographs, we do not know the competency of the installers or of the Harlor employee who carried out the visual inspection of the membranes. I appreciate that in retrospect it is not easy to evidence the installation process and that GeoDyne have stated that 'no further works or mitigation are necessary', however there are limitations to accepting information obtained from third parties. Aside from the gas requirements other recommendations were made in the 2015 reports which should also be verified: Evidence that the elevated soil plateau (comprised of waste materials) that was situated in the central-southern section of the site was removed? Was an asbestos survey carried out as recommended? Was any topsoil imported to the site for the garden areas? If so, was it certified as 'clean' and what depths were used? Was a watching brief carried out on site for previously unidentified contamination? In the circumstances I recommend that in order to satisfy part (iv) of condition 4 of H09-0706-19 the applicant should provide a verification report for the site. The report should include all of the points mentioned above and refer back to the recommendations made in the earlier 2015 reports. With regards to verification of the ground gas protection measures, I recommend that the report provides further evidence that the measures have been installed as outlined in the Supplementary Gas Report. I refer you to the YALPAG Verification Requirements for Gas Protection Systems document dated December 2016. I would suggest including photographs of the protection measures during construction, where possible, and as completed. Also, any correspondence from the NHBC, Building Inspectors or Harlor that back up the specification of the protection measures that were installed and the competency of the persons involved in the process.

Consult_Off_WM ODB127

The information contained in this email is confidential and intended only for the person or organisation to which it is addressed. If you have received it by mistake, please disregard and notify the sender immediately. Unauthorised disclosure or use of such information may be a breach of legislation or confidentiality and the content may be legally privileged. Any improper dissemination, forwarding, printing, or copying of this email is strictly prohibited. Emails sent from and received by employees of South Holland District Council may be monitored. They may also be disclosed to other people under legislation, particularly the Freedom of Information Act 2000, GDPR, the Data Protection Act 2018 and the Environmental Information Regulations 2004. If you have contacted the Council for a service any personal data you share will be used to help you access its services, or to answer your enquiry in line with our Privacy Policy. For full details of your rights please visit our website at www.sholland.gov.uk. Unless this

email relates to South Holland District Council business it will be regarded by the Council as personal and will not be authorised by or sent on behalf of the Council.