Online Comment

Application	H09-0926-26
Location	Land off Damgate Holbeach Spalding
Proposal	Details of construction management plan & method statement (Condition 18 of H09-0243-26)

Name	Diane Gordon
Address	SHDC Environmental Protection
Date Submitted	27-10-26
For/Against	Comments

No reference has been made to dust supression methods for construction activities and vehicle movements on site. please ensure a suitable and sufficient dust risk assesment is undertaken in accordance with IAQM construction dust guidance 2024 and submitted to publicprotection@sholland.gov.uk prior to comencement.