Online Comment

Application	H09-0930-17
Location	Bakkavor Freshcook Ltd Sluice Road Holbeach St Marks PE12 8HF
Proposal	Extension to Freshcook manufacturing facility to form WIP chill and stores. Removal of temporary chiller units

---

Name	Steve Branson
Address	Environmental Health Technician Safety and Environment
Date Submitted	31-10-17
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background level by more than 5dB(A)when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.