Online Comment

Application	H09-1076-16
Location	Manor Farm Marsh Road Holbeach Hurn PE12 8LR
Proposal	Proposed extension To existing 'Fresh Prepared' factory building

---

Name	Steve Branson
Address	Environmental Health Technician Safety and Environment

Date Submitted	11-11-16
For/Against	Comments

No objection but would wish to add the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute LA(eq) at any residential boundary not within the applicant's ownership.