OFFICE
OFFICE
FIRST AID
OFFICE
CUPBOARD
OFFICE
W.C.
SOAK TANKS
EXISTING FACTORY
EXISTING FACTORY
GROUND FLOOR
OFFICE
OFFICE
OFFICE
CUPBOARD
SOAK TANKS
EXISTING FACTORY
ROOF VOID
EXISTING FACTORY

PB — PUSH BAR IRONMONGERY WITH N7 PUSH BAR TO OPEN NOTICE
CARBON DIOXIDE EXTINGUISHER (2 Kg) TO B.S. EN3
FOAM FILLED EXTINGUISHER (6 litre) TO B.S. EN3
EMERGENCY LIGHTING POINT
E — EMERGENCY EXIT SIGN TO B.S. 5499 pt.1 75mm HIGH LETTERING
FIRE ALARM ACTUATING POINT
FIRE ALARM SOUNDER
SMOKE DETECTOR
30 min. FIRE DOOR WITH SELF CLOSER & LUMINESCENT STRIPS TO FRAME

revision	date	initials	revision details.
A	JAN '07	J.C.	ADDITIONAL SOAK TANKS
B	JAN '07	J.C.	OFFICE LAYOUT
C	JAN '07	J.C.	BUILDING LINE

ISSUE STATUS	ISSUE DATE

PLANNING & DEVELOPMENT
28 FEB 2007
Ref:

DETERMINED PLAN

AMENDED PLAN
Ref. A1

SHDC
PLANNING & DEVELOPMENT
28 FEB 2007

GODFREY CONSTRUCTION LTD
WEST BANK SUTTON BRIDGE
SPALDING LINC'S PE12 9DH
Tel : 01406 351188
Mobile : 07808 125 778
E-Mail : john@godfreyconstruction.co.uk

Client.
PREMIER FOODS LTD

Project.
PROPOSED EXTENSION TO FACTORY
BRIDGE ROAD
LONG SUTTON
SPALDING
LINC'S.

Drawing.
FLOOR PLANS - PROPOSED

Scale	1:100	Drawing No.	6025-02-C
Date.	DEC '06	Drawn.	J.C.