Online Comment

Application	H10-0358-20
Location	Princes Limited Bridge Road Long Sutton PE12 9EQ
Proposal	Proposed Private Sub-station Enclosure and Associated Transformer Compound

---

Name	Steve Branson
Address	South Holland District Council Priory Road
Date Submitted	17-07-20
For/Against	Comments

I note the objection raised regarding potential issues with low frequency noise due to the location of the sub-station. In the circumstances would ask that the applicant consider an alternative location for the substation at a greater distance from any residential properties.

If this is not something that applicant is able to do I would like to see an acoustic assessment that addresses the potential impact of noise on the surrounding residential properties with particular emphasis on low frequency noise along with any proposed mitigation measures.