Online Comment

Application	H10-0358-20
Location	Princes Limited Bridge Road Long Sutton PE12 9EQ
Proposal	Proposed Private Sub-station Enclosure and Associated Transformer Compound

---

Name	Steve Branson
Address	South Holland District Council Priory Road

Date Submitted	07-08-20
For/Against	Comments

No objection but would ask that the mitigation measures proposed in the acoustic report prepared by Waterman dated August 2020 be added as a condition. I.e. The generator to be housed in a brick built enclosure with southern acoustic louvred fa ade and an absorptive section of acoustic fence directly adjacent to the substation.