# Online Comment

| | |
|---|---|
| **Application** | H10-1235-21 |
| **Location** | Princes Limited Bridge Road Long Sutton PE12 9EQ |
| **Proposal** | Details of scheme to deal with contamination (Condition 3 of H10-0560-21) |

---

| | |
|---|---|
| **Name** | Sue Armour |
| **Address** | Environmental Protection Officer SHDC |
| **Date Submitted** | 20-12-21 |
| **For/Against** | Comments |

I have reviewed the information submitted as listed below. Although BS8285 is the more commonly referenced document with respect to the design of ground gas protection measures, CIRIA C665 has not been formally withdrawn, and giving weight to A.2.2.3 from BS8385, the actual building and the ground gas situation, I recommend discharge of condition 3 of H10-0560-21 in full.
PRINCES LTD. RAW MATERIALS WAREHOUSE. BRIDGE ROAD. LONG SUTTON.
Discharge of Conditions Application to Consent H10-0560-21 (dated 10 September 2021)
PLRMW-BBA-Z0-XX-RP-A-00010 S2 P1 29 November 2021
Solmeck Ground Gas Risk Assessment 29/1/2019
APEX Demolition Addendum for 200mm Asbestos Soils Surface Scrape
CHEMtest Test data dated 9/7/2019
AM-20190710095140 AIR SAMPLING TEST CERTIFICATE
Weighbridge Tickets
99/3603 BBA CERTPOLYTHENE (Membrane detail)
PLSRMW-ONE-ZZZ-L00-DR-S-4205 (CR) Structural Level 00 Ground Bearing Slab Details
Mark Cooper email 20/12/21