

Online Comment

Application H11-0053-25
Location HOLMHURST 24 WISBECH ROAD LONG SUTTON PE12 9AG
Proposal Alterations to Outbuilding

Name Diane Fairchild
Address Conservation Assistant (Tree Preservation) Planning & Development

Date Submitted 18-02-25
For/Against Comments

No objections to proposal.
Suggest that should consent be granted, that the usual Tree Protection Conditions as described in British Standard BS 5837: 2012 are added to the Decision Notice.

To protect soil in the Root Protection Areas (as calculated in British Standard BS 5837: 2012) from soil compaction, which can damage roots, and protection from accidental branch damage, during the proposed dismantling and reconstruction process. If Root Protection Areas are not calculated, allow a distance of at least 1-2 metres outside of the natural* canopy spread. (*Spread should tree never have been pruned.)