Council Offices
Priory Road
Spalding
Lincolnshire
PE11 2XE
Admin 01775 764725
DC Officers 01775 764703

planningadvice@sholland.gov.uk
www.sholland.gov.uk

G R Merchant Ltd
Unit 4 Wrights Mews
12a Park Road
Holbeach
Spalding
PE12 7EE

TOWN AND COUNTRY PLANNING ACT 1990

FULL

Reference: H11-0174-23 **Date of Decision:** 11th May 2023

Applicant: Mr & Mrs S Wells
Riseholme Lodge
Charters Lane
Long Sutton
Spalding
PE12 9JX

Location: Land Adj 17 Trafalgar Square Long Sutton Spalding

Description: Residential Development

South Holland District Council hereby give notice that permission has been GRANTED (or equivalent) subject to the following condition(s):

1 The development must be begun not later than the expiration of three years beginning with the date of this permission.

Reason: As required by Section 91 of the Town and Country Planning Act 1990 as amended by the Planning and Compulsory Purchase Act 2004.

2 The development hereby permitted shall be carried out in accordance with the following approved plans and/or documents:

4102-22 01
4102-22 02D
Flood Risk Assessment by Ellingham Consulting Ltd dated February 2023

Reason: For the avoidance of doubt and in the interests of proper planning.

3 Before the new access is brought into use, the existing hedge shall, be lowered to, and at

all times thereafter maintained at, a height not exceeding 0.6 metres above the edge of the adjacent carriageway for a distance of 12.0 metres approximately on the northern side of the access.

Reason: To allow sufficient visibility to drivers entering/existing the site and in the interests of highway safety.
This Condition is imposed in accordance with Policies 2 and 3 of the South East Lincolnshire Local Plan, 2019.

4 The development hereby permitted shall be carried out in accordance with the measures set out in the Flood Risk Assessment (by Ellingham Consulting Ltd dated February 2023) forming part of this planning application, unless otherwise agreed in writing by the Local Planning Authority, in particular the following measures shall be fully implemented before the property is first occupied:

- Finished Floor levels of the dwelling shall be +3.5m OD, 1.0m above the lowest ground level at the site
- It is recommended that there is 0.3m of flood resilient construction above finished floor levels
- The applicant should sign up with the Environment Agency for flood warnings

Note: The above approved plan does not constitute final approval of detailed site levels or finished floor levels.

Reason: To ensure that the development does not increase the risk of flooding or be at risk of flooding.
This Condition is imposed in accordance with Policies 3 and 4 of the South East Lincolnshire Local Plan, 2019 and national guidance contained in Section 14 of the National Planning Policy Framework, 2021.

5 The scheme of landscaping and tree planting shown on dwg. no. 4102-22 02D shall be carried out and completed in its entirety during the first planting season following practical completion of the development. All trees, shrubs and bushes shall be maintained by the owner or owners of the land on which they are situated for the period of five years beginning with the date of completion of the scheme and during that period all losses shall be made good as and when necessary.

Reason: To ensure that the development is adequately landscaped, in the interests of its visual amenity and that of the area in which it is set.
This Condition is imposed in accordance with Policies 2 and 3 of the South East Lincolnshire Local Plan, 2019.

6 Five swift nest bricks shall be incorporated within the external walls of the dwelling hereby approved and shall be retained thereafter.

Reason: In the interests of biodiversity.
This Condition is imposed in accordance with Policy 28 of the South East Lincolnshire Local Plan, 2019.

7 The water consumption of the dwelling hereby permitted should not exceed the

requirement of 110 litres per person per day (as set out as the optional requirement in Part G of the Building Regulations 2010 and the South East Lincolnshire Local Plan, 2019). The person carrying out the work must inform the Building Control Body that this duty applies. A notice confirming the requirement for the water consumption has been met shall be submitted to the Building Control Body and Local Planning Authority, no later than five days after the completion of the dwelling.

Reason: To protect the quality and quantity of water resources available to the district. This Condition is imposed in accordance with Policy 31 of the South East Lincolnshire Local Plan, 2019.

Notes:

The Local Planning Authority has acted positively and proactively in determining this application by assessing it against all material considerations, including national guidance, planning policies and representations that have been received during the public consultation exercise, and by identifying matters of concern within the application and negotiating, with the Applicant, acceptable amendments to the proposal to address those concerns. As a result, the Local Planning Authority has been able to grant planning permission for an acceptable proposal.

This decision notice, the relevant accompanying report and the determined plans can be viewed online at http://planning.sholland.gov.uk/OcellaWeb/planningSearch

South Holland Internal Drainage Board has advised the applicant has indicated that they intend to dispose of surface water via infiltration, however the viability of this proposal has not been evidenced. It is recommended that ground investigation is carried out to determine infiltration potential, followed by testing in line with BRE Digest 365 if onsite material is considered favourable for infiltration. If infiltration is not feasible at this site, following the drainage hierarchy the applicant would be expected to propose discharge surface water to a watercourse. In this case, consent would be required from South Holland Internal Drainage Board under Byelaw 3. Please note that any discharge should be in line with the Non-Statutory technical standards for sustainable drainage systems (SuDS), therefore the Board is unlikely to grant consent for discharges in excess of greenfield rate.

It is noted that the applicant intends to dispose of foul water to a main sewer. Should the applicants proposals change to include the discharge of treated foul water to a watercourse, consent would be required under Byelaw 3.

The applicant should confirm if there are any riparian owned/maintained watercourses within or adjacent to the site boundary. Should the applicant's proposals include works to alter a watercourse, or if works are proposed to alter a watercourse at any time in the future, consent would be required under the Land Drainage Act 1991 (and byelaw 4).

The permitted development requires the formation of a new/amended vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. The works should be constructed in accordance with the Authority's specification that is current at the time of construction. Relocation of existing

apparatus, underground services or street furniture will be the responsibility of the applicant, prior to application.

For application guidance, approval and specification details, please visit:
https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb
or contact vehiclecrossings@lincolnshire.gov.uk

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works.

For further guidance please visit:
Traffic Management - https://www.lincolnshire.gov.uk/traffic-management
Licences and Permits - https://www.lincolnshire.gov.uk/licences-permits



Phil Norman
Head of Planning
South Holland District Council

BUILDING REGULATIONS:
This decision refers only to planning permission as granted under the Town and Country Planning Act 1990. The works that you are proposing may also require Building Regulations and this planning permission does not give authority under Building Regulations to commence work. Please contact the Building Control section for further information on 01775 764557 or bcadmin@sholland.gov.uk

RIGHTS OF APPEAL

Appeals to the Secretary of State

If you are aggrieved by the decision of your Local Planning Authority to refuse permission for the proposed development or grant consent subject to conditions, then you can appeal to the Secretary of State under Section 78 of the Town and Country Planning Act 1990 or Section 20 of the Planning (Listed Building and Conservation Areas) Act 1990.

Timescales for appealing

The deadlines for appeals are calculated from the **date of decision** and are as follows for the types of applications below:

12 Weeks	6 Months	8 Weeks
Householder Applications	Planning Permission	Consent to Display Adverts
Minor Commercial Development	Listed Building Consent	
Agricultural Determinations	Other Prior Approval Applications	
Householder Prior Approval Applications		

https://www.gov.uk/appeal-householder-planning-decision

https://www.gov.uk/appeal-planning-decision

If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planning inspectorate.gov.uk) at least 10 days before submitting the appeal. Further details are on GOV.UK.

Enforcement Notices

If an enforcement notice was served prior to the planning application being determined then the deadline for appealing is 28 days from the date of the **planning refusal**.

If an enforcement notice is served after the planning application is determined then the deadline for appealing is 28 days from the date of the **enforcement notice** OR **the timescales stated above for each application type** from the date of the planning refusal - whichever is sooner.

Appeals can be made online at: https://www.gov.uk/planning-inspectorate. If you are unable to access the online appeal form, please contact the Planning Inspectorate to obtain a paper copy of the appeal form on tel: 0303 444 5000.

The Secretary of State can allow a longer period for giving notice of an appeal but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in

giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to the Secretary of State that the Local Planning Authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under the order.

Purchase Notices

If either the Local Planning Authority or the Secretary of State refuses permission to develop land or grant it subject to conditions the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor can he render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances the owner may serve a purchase notice on the Council in whose area the land is situated. This notice will require the Council to purchase his interest in the land in accordance with the provisions of the Part VI of the Town and Country Planning Act 1990 or Section 32 of the Planning (Listed Building and Conservation Areas) Act 1990.

Compensation

In certain circumstances compensation may be claimed from the Local Planning Authority if permission is refused or granted subject to conditions by the Secretary of State on appeal or on reference of the application to him.

These circumstances are set out in Section 114 and related provisions of the Town and Country Planning Act 1990 and Section 27 of the Planning (Listed Building and Conservation Areas) Act 1990.