

Online Comment

Application H11-0424-19
Location Station Road Long Sutton
Proposal Details of Condition 4 (estate roads), 5 (surface water drainage), 6 (foul water disposal), 7 (land contamination), 8 (construction management), 9 (landscaping), 10 (landscape management & maintenance), 11 (lighting), 12 (boundary treatment), 13 (external materials), 14 (gas & electricity box) and 16 (Site/floor levels) of H11-0916-16

Name Sue Armour
Address Environmental Protection Officer SHDC, Priory Road Spalding PE11 2XE

Date Submitted 21-05-19
For/Against Comments

I have reviewed the Ground Engineering Limited 'Remediation Method Statement Nene Transport (Lincs) Depot, Station Road, Long Sutton, Lincs' Ref C13684A dated 12th April 2019. The proposal is generally suitable subject to the following points:

1. When inspecting the excavations in garden areas, photographs must show the depth of soil excavated.
2. No details of the proposed sampling schedule and rate for imported soil. Acceptable rates are given in the YALPAG technical guidance 'Verification Requirements for Cover Systems'. The letter report should be reissued to reflect the above points. At which time I will be able to recommend discharge of condition 7i of H11-0916-16, with part ii remaining outstanding.