Online Comment

Application	H11-0488-17
Location	WINDMILL GARAGE 34 WISBECH ROAD LONG SUTTON PE12 9AG
Proposal	Residential development

Name	J Reith
Address	Environmental Health Technician Safety and Environment
Date Submitted	14-06-17
For/Against	Comments

Further to the GeoEnvironmental Desk Study by Goldfinch Environmental Ref 0427/1 dated April 2017 I request parts 2 - 4 of the contaminated land condition. I disagree with the statement in the report that further investigation is unwarranted, particularly due to the underground and above ground storage tanks which are still in situ. The soil around the above ground tank requires investigation and I require testing to be carried out in the area around the underground storage tanks once they have been excavated. This is to confirm whether there have been any leaks from the tanks.