Online Comment

Application	H11-0506-21
Location	Former Nene Transport Station Road Long Sutton
Proposal	Details of scheme to deal with contamination and construction management plan details (Conditions 7 and 8 of H11-0916-16)

Name	Sue Armour
Address	Environmental Protection Officer SHDC PE11 2XE
Date Submitted	13-10-21
For/Against	Comments

I have reviewed the Emcus Limited 'Supplementary remediation method statement for GEDA Construction Limited on a site at Station Road, Long Sutton, Spalding, Lincolnshire' ref MJH/J2011/D1/2 Revision 2 dated 1st October 2021 and 'GEDA Construction 'Construction Management Plan Rev A Long Sutton, Spalding, PE12 9BP Construction Works for the erection of 40no. Residential dwellings - chapter 14 soil remediation in back gardens' rev A dated 5/10/2021 and have no objections to the proposed plans.

My only comments are that if the proposed soil for importation is manufactured, from a recycled or brownfield source, or has been stockpiled away from its original source, then asbestos should be included in the testing suite. I look forward to the receipt of the validation report in due course.