

ASBESTOS FIBRE IDENTIFICATION REPORT.

Report/Job No: J029773

Final Issue Date: 08/06/2016



Private & Confidential:
PASS UK Ltd
Litton House
Global Business Park
Saville Road
Peterborough
PE3 7PR

Premises Of Sample Origin:
Olivera
2 Roman Bank
Longsutton
PE12 9LA

Millers Barn
The Warren Estate
Lordship Road
Writtle
Chelmsford
Essex
CM1 3WT
Tel: 01245 422800
Fax: 01245 422501
info@cavendishlaboratories.com

Name of analyst: Paul Jarvis
Date of sample receipt: 06/06/2016

Sampled by: Client
Date of analysis: 08/06/2016

Results:

Laboratory Sample Ref.	Sample Location and Description	Asbestos Fibre Type	Presumptive Product Type
BS074529	BROOKER/0306/01 - Roof lean to	Chrysotile	Cement product

Chrysotile= "White asbestos", Amosite= "Brown asbestos", Crocidolite = "Blue asbestos"

Refer to H.S.E. publication HSG 264, for the approximate percentage asbestos content within the presumptive product type.

Method Statement and Disclaimers:

The analysis of the sample(s) detailed on this report is U.K.A.S. accredited. Analysis was performed in accordance with our quality control manual in-house method and Health & Safety Executive publication HSG 248.

Any interpretations or opinions expressed in this report are outside the scope of U.K.A.S accreditation.

Cavendish Laboratories Ltd does not hold U.K.A.S. accreditation for on-site sampling of suspected asbestos materials.

The stated "presumptive product type" is a subjective assessment by our analyst, it is not determined by measurement and it is an opinion. Cavendish Laboratories Ltd. cannot accept responsibility for any discrepancy or inaccuracy arising from collection or labelling of samples by the client. U.K.A.S. stands for United Kingdom Accreditation Service.

Authorised Signatory:

Paul Jarvis FA004-11 (5/12/13)