Online Comment

Application	H11-0759-19
Location	The Abattoir Bull Lane Long Sutton PE12 9HA
Proposal	Erection of detached three bedroom house

Name	Sue Armour
Address	Environmental Protection Officer SHDC, Priory Road Spalding PE11 2XE
Date Submitted	26-09-19
For/Against	Comments

I have reviewed the Harrison Geotechnical Consulting Ltd Desk study report 'The Abattoir, Long Sutton' ref GN22839 dated August 2019.

The report has identified past industrial use as an abattoir and identified that further site investigation is required in order to determine if remedial action is needed to make the site suitable for use.
I therefore request that the following condition be applied:
The development hereby permitted shall not be commenced until a scheme to deal with any contamination of land or pollution of controlled waters has been submitted to and approved in writing by the Local Planning Authority (LPA) and until the measures approved in that scheme have been implemented. The scheme shall include all of the following measures unless the LPA dispenses with any such requirement in writing.

i) A site investigation shall be carried out to fully and effectively characterise the nature and extent of any land contamination and/or pollution of controlled waters. It shall specifically include a risk assessment that adopts the Source-Pathway-Receptor principle, in order that any potential risks are adequately assessed taking into account the sites existing status and proposed new use. Two full copies of the site investigation and findings shall be forwarded to the LPA without delay upon completion.

ii)Thereafter, a written method statement detailing the remediation requirements for land contamination and/or pollution of controlled waters affecting the site shall be submitted to and approved in writing by the LPA, and all requirements shall be implemented and completed to the satisfaction of the LPA. No deviation shall be made from this scheme without the express written agreement of the LPA. If during redevelopment contamination not previously considered is identified, then the LPA shall be notified immediately and no further work shall be carried out until a method statement detailing a scheme for dealing with the suspect contamination has been submitted to and agreed in writing by the LPA.

iii) Two full copies of a full closure report shall be submitted to and approved in writing by the LPA. The report shall provide verification that the required works regarding contamination have been carried out in accordance with the approved Method Statement(s). Post-remediation sampling and monitoring results shall be included in the closure report to demonstrate that the required remediation has been fully met. Note: The applicant is advised that the phased risk assessment required by the Contaminated Land Scheme Condition should be carried out in accordance with the procedural guidance of the Environmental Protection Act 1990 Part 11A.