Online Comment

Application	H11-0954-22
Location	15 WEST STREET LONG SUTTON SPALDING PE12 9BN
Proposal	New external fridge plant to rear of building

Name	Steve Branson
Address	SHDC Priory Road
Date Submitted	02-11-22
For/Against	Comments

No objection.
Request the following condition:
Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.