SOUTH HOLLAND DISTRICT COUNCIL

Town and Country Planning Act 1990

Approval required by Condition of Planning Permission

Reference: H11/1220/95 Received:18-DEC-95 Type:CONDITION COMPLIANCE

Earlier Permission: H11/0150/94

Name: Mr J R Russell
The Chalet
Hospital Drove
Long Sutton
Spalding Lincs

Agent: Mr J R Russell
The Chalet
Hospital Drove
Long Sutton
Spalding Lincs

Description: Details of fume extraction/ arrestment equipment (Condition 3 of application H11/0150/94)
Location : 48 Market Place Long Sutton
Spalding Lincs

South Holland District Council hereby give notice that CONSENT HAS BEEN GRANTED for the details submitted for the purpose of conditions attached to the planning permission, subject to any conditions below:

You are advised the maximum residential boundary noise level in respect of the use of the extraction system should not exceed 40 LA eq. 5 minutes. For any information in respect of this noise level, contact should be made with the Director of Environmental Services of this Authority.

Director of Housing and Planning Services
25-MAR-96 H11/1220/95

This decision refers only to that required for the purposes of the Town and Country Planning Act and not for Building Regulations or any other legislation. See enclosed notes relating to rights of appeal.

MRS SALLY WALTHAM BA (Hons) F.C.I.H. Director of Housing & Planning Services

Housing & Planning Services Department, Council Offices, Priory Road, Spalding, Lincolnshire. PE11 2XE (Tel: 01775 761161)

Town and Country Planning Act etc

DRAFT PERMISSION

Reference: H11/1220/95 Received:18-DEC-95 Type:CONDITION COMPLIANCE

Name: Mr J R Russell
The Chalet
Hospital Drove
Long Sutton
Spalding Lincs

Agent: Mr J R Russell
The Chalet
Hospital Drove
Long Sutton
Spalding Lincs

Description: Details of fume extraction/ arrestment equipment (Condition 3 of application H11/0150/94)
Location : 48 Market Place Long Sutton
Spalding Lincs

South Holland District Council hereby give notice that permission has been granted (or equiv) on the following condition(s):

You are advised the maximum residential boundary noise level in respect of the use of the extraction system should not exceed 40 LA eq. 5 minutes. For any information in respect of this noise level, contact should be made with the Director of Environmental Services of this Authority.

13-MAR-96

AD check....A.13/3...

Authorised to issue (inc Delegation).....A.13/3