Online Comment

Application	H11-1264-18
Location	Land off Lime Walk Long Sutton PE12 9HG
Proposal	Proposed residential development

Name	Ruth Dowling
Address	Building Control South Holland District Council

Date Submitted	17-01-19
For/Against	Comments

Where private Drives exist provision should be made for Fire Appliances and Rubbish Trucks, Rubbish should not be carried no further than 30m from the property.