Online Comment

Application	H12-0069-21
Location	The Smallholding Green Dyke Lutton PE12 9LW
Proposal	Erection of building for use for germination/testing - retrospective (previously approved under H12-0972-15)

Name	Steve Branson
Address	SHDC Priory Road
Date Submitted	25-03-21
For/Against	Comments

No objection but would wish to attach the following condition:
Noise from fixed plant and machinery shall not exceed the background noise by more than 5 dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.