Online Comment

Application	H12-0139-26
Location	84 Little London Long Sutton Spalding PE12 9LF
Proposal	Details of External Lighting (Condition 17 of H12-0310-24)

Name	Diane Gordon
Address	Environmental Protection SHDC
Date Submitted	13-03-26
For/Against	Comments

the The lighting lux mapping and technical specifications have been assessed.
ensure the lighting column closest to Number 90 side boundary is suitably shielded or controlled by timer to avoid potential light nuisance to the nearby residents