
David Trundley Design Services

White House Farm, Tilney All Saints, King's Lynn, Norfolk, PE34 4RU. Tel:- 01945 880696
E-mail: dtrundleydesign@aol.com Fax:- 01945 881266

Our Ref: 01/124 **Your Ref:** H13/1088/02

Date: 16th January 2003

South Holland District Council
Council Offices
Priory Road
Spalding
Lincs
PE11 2XE



For the attention of Mr D Gedney

Dear Sirs

W EMMETT & SON, WASHWAY ROAD, FOSDYKE, SPALDING, LINCS.
MODIFICATION TO CONDITION 7 OF H13/0511/02.

Further to the granting of planning approval on the 23rd December 2002 we enclose herewith drawing number 01-124-78A indicating the location, cross section and constructional details of the proposed acoustic screen for compliance with condition.

The acoustic screen proposed has been undertaken in various locations throughout the country to provide an effective noise reduction barrier to adjacent residential properties.

The basic concept is to deflect the noise back to its original source not try to absorb the noise which from previous experience does not provide a long term solution. The scheme is simple but provides an effective noise deflection barrier and provide a low maintenance long term solution to the issue.

The scheme is of a simple construction nature but also sympathetic to its location i.e. being constructed in timber boarding, etc.

We enclose 4 copies of drawing 01-124-78A for your information.

Yours faithfully

I. Trundley.

I P G Trundley MBIAT

PLANNING AMENDMENT

For office use only

Application No. H13/0045/03/41

Date Registered 04 APR 2003

Case Officer JG

1. Please complete in block letters

NAME AND ADDRESS OF APPLICANT

W Emmett + Son
Washway Rd
Fosdyke

Tel. No.

NAME AND ADDRESS OF AGENT
(if form completed by agent)

David Trundley

Tel. No. (Contact)

Please complete in block letters

FULL POSTAL ADDRESS OF THE APPLICATION SITE

As Above

Please complete

APPLICATION No.

This amendment **cannot be considered** unless the relevant reference is stated

H13/0045/03

Building Regulation reference relating to same development (if any)

2. Please tick **one** box only

A — Amendment is proposed where permission already granted
If yes, submit two forms and two plans. ☑

or

B — Amendment is to a proposal currently being considered ☐
If yes, submit four forms and four plans.

Please complete

I attach the necessary plans and request that the changes described below be accepted as an amendment. I understand that the Council may require a fresh application, together with fee if appropriate. If the amendment relates to a current application, I agree to an extension of the terminal date.

Signed ..... Date .....

3. Please complete in block letters

FULL DESCRIPTION OF DEVELOPMENT IN ORIGINAL APPLICATION

Acoustic Screen

State details of amendments proposed

(Give a full detailed list of the changes, and also mark these clearly on the accompanying plans. Only the changes listed here will be considered.)

See letter

State drawing no's of the current submission

Has this amendment been requested by the Council? (If so, state Officer dealing with the application)

YES / NO

Describe any part of the original development which is excluded by virtue of the amendment, and state any alteration to plot numbers

Has a similar amendment been submitted under Building Regulations? Yes / No

FILE COPY

SOUTH HOLLAND DISTRICT COUNCIL

Terry Huggins
Acting Chief Executive
Andrew Petcher
Acting Director of Customer Services
Bob Atkins
Director of Corporate Services

Application no: H13/0045/03

Original Applicant
W Emmett & Son
Washway Road
Fosdyke
Spalding
Lincs

Original Agent:
David Trundley Design Services
White House Farm
Tilney All Saints
Kings Lynn
Norfolk PE34 4RU

Description: Details of Acoustic Screen (Condition 1 of H13/1088/02)

Location: Washway Road
Fosdyke

Amendment: Revised Acoustic Screen Details

25-APR-03

Dear Sir/Madam

TOWN AND COUNTRY PLANNING ACT 1990

NOTICE OF ACCEPTANCE OF AMENDMENT

The amended details submitted in respect of the above proposal have now been considered and there are no objections to the amendment being implemented to the extent described above.

Note: This Notice does not convey any approval under the Building Regulations and you may need to make a new submission.

Yours faithfully

Head of Planning & Development

Council Offices
Priory Road
Spalding
Lincolnshire
PE11 2XE

Telephone: (01775) 761161
Fax: (01775) 711253
Email: info@sholland.gov.uk

AMENDMENT RECORD SHEET - POST DECISION

Admin

Validation:

Inadequate/Inappropriate ☐

Clarification/Details required:

Appears valid ☐

Registered .....

DC Procedural Assessment

Is the information given correct? Yes/~~No~~ (If No, state above what details are needed)

Is it an amendment in principle? Immaterial/~~Needs new app~~

Confirmed: .....

Give a revised description if the details accepted are different to the submission:

Acceptance issued:

Application Amendments

Application H13/0045/03

Location Washway Road
Fosdyke

Postcode House Number

Amendment 1 Date 09-04-2003

Type POS Post-Decision
Sub-Type

Description Revised Acoustic Screen Details

Long Description

Agent Des'n
Name David Trundley Design Services
Address White House Farm
Tilney All Saints
Kings Lynn
Norfolk PE34 4RU
Post Code E-Mail
Tel 01945 880696 Fax 01945 881266
Ref

David Trundley Design Services

White House Farm, Tilney All Saints, King's Lynn, Norfolk, PE34 4RU. Tel:- 01945 880696
E-mail: dtrundleydesign@aol.com Fax:- 01945 881266

SOUTH HO
- 4 APR 2003
DG
ENDED PL

Our Ref: 01/124

Your Ref:

Date: 3rd April 2003

South Holland District Council
Council Offices
Priory Road
Spalding
Lincs
PE11 2XE

For the attention of Mr D Gedney

Dear Mr Gedney

EMMETT (UK), WASHWAY ROAD, FOSDYKE, SPALDING, LINCS.
PROPOSED ACOUSTIC SCREEN

Further to the granting of planning permission 0045/03 our client has now obtained various quotations for the works and have had an alternative equivalent proprietary system proposed.

We have checked the alternative against the original design and are satisfied that the requirements are fully compliant. The noise barrier will be 4m (as original spec) with sawn soft wood timber reflective noise barrier designed in accordance with BS EN 1793: Part 2: 1997. All timber panels to be fixed to and including galvanised steel RSJ posts set into ground and concreted. All timber shall be pressure treated to BS 5589 Category A (40 year design life) and be treated in brown (celbronze) colour.

Due to the sensitive nature of the site we feel that it is only correct that you are aware of minor change and would welcome your written approval of change prior to the construction of the screen.

We look forward to your response.

Yours sincerely

I. Trundley.

I P G Trundley MBIAT

cc. FJC Food Projects – E Getley