

DECISION DELEGATED TO HEAD OF PLANNING

Application No: H13-0316-25 **Applicant:** Mr J Perowne
Proposal: Installation Of Roof Mounted Solar PV Panels
Location: Jack Bucks Farm Green Lane Moulton Seas End
Terminal Date: 23rd May 2025

Planning Policies

South East Lincolnshire Local Plan - Adopted: March 2019

National Guidance

National Planning Policy Framework December 2024

Part 14, Class J of the General Permitted Development Order (2015) (as amended)

Representations:

	Object	Support	No Obj.	Comments
PARISH COUNCIL	0	0	0	0
WARD MEMBER	0	0	0	0

CASE OFFICER ASSESSMENT

Proposal

This is a prior approval application for the proposed installation roof mounted photovoltaic solar panels at Jack Bucks Farm, Green Lane in Moulton Seas End.

Site Description

The application site is part of the Jack Bucks Farm. The land sits to the north of the main Jack Bucks Farm. Open agricultural land lies to the north and west with neighbouring dwellings to the further east.

History

H13-0508-22 - Full - Proposed extension to celeriac grading building - Approved 13.07.2022

H13-0593-20 - Prior Approval - Proposed roof mounted solar panels - Approved 14.09.2020

H22-1078-18 - Section 72 - Retention of dwelling without complying with agricultural habitation clause (Condition 3 of SR93-65) - Approved 11.12.2018

H13-1070-18 - Full - Proposed celeriac grading building - Approved 10.12.2018

H13-0944-18 - Full - New vehicular access to B1357 - Approved 15.11.2018

H13-0192-13 - Full - Store and hardstanding area extensions, plus a rainwater recycling building - Approved 08.05.2013

Consultation Responses

This application has been advertised in accordance with the Development Procedure Order and the Council's Statement of Community Involvement. In this instance, no consultee responses have been received.

Public Representation

This application has been advertised in accordance with the Development Procedure Order and the Council's Statement of Community Involvement. In this instance, no letters of representation have been received.

Planning Considerations

Class J, Part 14 of the General Permitted Development Order (2015) (as amended)

Class J, Part 14 of the General Permitted Development Order outlines the following.

The installation, alteration or replacement of -

- (a) microgeneration solar thermal equipment on a building;
- (b) microgeneration solar PV equipment on a building; or
- (c) other solar PV equipment on the roof of a building, other than a dwellinghouse or a block of flats.

J.1 Development is not permitted by Class J if -

- (a) the solar PV equipment or solar thermal equipment would be installed on a pitched roof and would protrude more than 0.2 metres beyond the plane of the roof slope when measured from the perpendicular with the external surface of the roof slope;
- (b) the solar PV equipment or solar thermal equipment would be installed on a flat roof, where the highest part of the solar PV equipment would be higher than 1 metre above the highest part of the roof (excluding any chimney);
- (c) the solar PV equipment or solar thermal equipment would be installed on a roof and within 1 metre of the external edge of that roof;
- (e) the solar PV equipment or solar thermal equipment would be installed on a site designated as a scheduled monument; or
- (f) the solar PV equipment or solar thermal equipment would be installed on a listed building or on a building within the curtilage of a listed building.

J.2 Development is not permitted by Class J(a) or (b) if -

- (a) the solar PV equipment or solar thermal equipment would be installed on a wall and would protrude more than 0.2 metres beyond the plane of the wall when measured from the perpendicular with the external surface of the wall;
- (b) the solar PV equipment or solar thermal equipment would be installed on a wall and within 1 metre of a junction of that wall with another wall or with the roof of the building; or
- (c) in the case of a building on article 2(3) land, the solar PV equipment or solar thermal equipment

would be installed on a wall which fronts a highway.

Assessment

When assessed against the above criteria the following can be observed:

J.1.(a) The panels do not protrude more than 0.2 metres beyond the plane of the roof slope.

J.1.(b) No solar equipment is to be installed on a flat roof.

J.1.(c) None of the solar equipment is within 1 metre of any roof edge.

J.1.(e) The solar panels will not be installed on scheduled monument.

J.1.(f) The solar panels will not be installed on a listed building or within the curtilage of a listed building.

J.2.(a) The solar equipment will not be installed on a wall.

J.2.(b) The solar equipment will not be installed on a wall.

J.2.(c) The solar equipment will not be installed on a building on Article 2 (3) land.

The proposal accords with all of the relevant prior approval criteria.

Additional Considerations

Public Sector Equality Duty

In making this decision the Authority must have regard to the public sector equality duty (PSED) under s.149 of the Equalities Act. This means that the Council must have due regard to the need (in discharging its functions) to:

A. Eliminate unlawful discrimination, harassment and victimisation and other conduct prohibited by the Act

B. Advance equality of opportunity between people who share a protected characteristic and those who do not. This may include removing or minimising disadvantages suffered by persons who share a relevant protected characteristic that are connected to that characteristic; taking steps to meet the special needs of those with a protected characteristic; encouraging participation in public life (or other areas where they are underrepresented) of people with a protected characteristic(s).

C. Foster good relations between people who share a protected characteristic and those who do not including tackling prejudice and promoting understanding.

The protected characteristics are age, disability, gender reassignment, pregnancy and maternity, race, religion or belief, sex and sexual orientation.

The PSED must be considered as a relevant factor in making this decision but does not impose a duty to achieve the outcomes in s.149. It is only one factor that needs to be considered, and may be balanced against other relevant factors.

It is not considered that the recommendation in this case will have a disproportionately adverse impact on a protected characteristic.

Human Rights

In making a decision, the Authority should be aware of and take into account any implications that may arise from the Human Rights Act 1998. Under the Act, it is unlawful for a public authority such as South Holland District Council to act in a manner that is incompatible with the European Convention on Human Rights. The Authority is referred specifically to Article 8 (right to respect for private and family life) and Article 1 of the First Protocol (protection of property).

It is not considered that the recommendation in this case interferes with local residents' right to respect for their private and family life, home and correspondence, except insofar as it is necessary to protect the rights and freedoms of others (in this case, the rights of the applicant). The Council is also permitted to control the use of property in accordance with the general public interest and the

recommendation is considered to be a proportionate response to the submitted application based on the considerations set out in this report.

Conclusion

The proposal accords with criteria within Class J, Part 14 of the General Permitted Development Order (2015); and therefore, the recommendation is for delegated approval.