

Online Comment

Application H13-0424-22
Location Eaugate Road Moulton Chapel Spalding
Proposal Details of scheme to deal with contamination (Condition 12 parts i and ii of H13-1269-21)

Name Sue Armour
Address Environmental Protection Officer SHDC

Date Submitted 09-06-22
For/Against Comments

I have reviewed the Ground Engineering Limited 'REPORT ON A CONTAMINATION ASSESSMENT AT FORMER AGRICULTURAL PREMISES EAUGATE ROAD MOULTON EAUGATE SPALDING LINCOLNSHIRE Report Reference C15587' dated April 2022. I am in general agreement with the findings and proposals for remediation and look forward to the receipt of the remediation method statement in due course. In order to adequately characterise the ground gas regime at a given location, we look to receive the data form at least 6 monitoring visits. All three of the visits presented here were at relatively high pressure, and there was no comment regarding the atmospheric conditions in the proceeding days, therefore we would look to the RMS to provide further consideration that the CS1 classification was appropriate.

I therefore recommend discharge of condition 12 parts i & ii of H13-1269-21, with 12iii and 13 remaining outstanding.