

PLANNING AMENDMENT

For Office Use only

Application No:

Date Registered:

Case Officer:



(Please complete using block capitals and black ink)

APPLICANT NAME AND ADDRESS MOULTON BULB COMPANY LTD. LONG LAKE, MOULTON, Lincs - PE12 6PP Telephone: 01406 370380	AGENT NAME AND ADDRESS Telephone:
SITE ADDRESS DETAILS SAME AS ABOVE	
CURRENT APPLICATION NO: This amendment cannot be considered unless the relevant reference is stated.	H13 - 0675 - 25
Building Regulation reference relating to same development (if applicable)	N/A

I attach four copies of this form and necessary plans and request that the changes described below can be accepted as an amendment. As the amendment relates to a current application.

Signed: [REDACTED]

Date: 15/09/2025

FULL DESCRIPTION OF DEVELOPMENT OF CURRENT APPLICATION THAT THIS AMENDMENT RELATES TO	INSTALLATION OF 5 LPG BULK TANKS ON CONCRETE PAD TO INCREASE TOTAL LPG CAPACITY ONSITE TO 45 TONNES - RETROSPECTIVE	
State details of amendments proposed. (Give a full detailed list of the changes; and also mark these clearly on the accompanying plans. Only the changes listed here will be considered)	FURTHER DETAILS REQUIRED CONFIRMATION FROM DAVID GLADMAN - HSE SPECIALIST INSPECTOR (MAJOR HAZARDOUS RISK ASSESSMENT). APPLICATION ALTERED ACCORDINGLY. PTO.	
State drawing numbers of the current submission	2011 - 01 - E	
Has this amendment been requested by the Council? (If so, state Officer dealing with the application)	YES/NO	*
Describe any part of the original development which is excluded by virtue of the amendment, and state any alteration to plot numbers	N/A	
Has a similar amendment been submitted under Building Regulations? (If so, state Building Control Surveyor dealing with application)	YES/NO	

* APPLICATION FOR HAZARDOUS SUBSTANCE CONSENT REQUESTED BY DAVID GLADMAN - HSE SPECIALIST INSPECTOR (MAJOR HAZARDOUS RISK ASSESSMENT) VERSION 2 SENT BY CW 13/09/25

• SECTION 5(d)

- MAXIMUM LPG TANKER SIZE IN TOWNES CONFIRMED.
- FREQUENCY OF LPG DELIVERIES FOR EACH SET OF TANKS STATED IN THE APPLICATION
- TANK FILLING PROCESS CONFIRMED AS INDIVIDUALLY FILLED.

• TABLE A, TABLE B, TABLE C (i), TABLE D AND TABLE 5(d)

- CONFIRMED THAT THE GAS TANKS ONSITE WILL ONLY BE FILLED WITH PROPANE. THE TANKS ONSITE WILL NOT BE FILLED WITH N-BUTANE