

Online Comment

Application H13-0705-18
Location Adjacent: 33 Pipwell Gate Moulton Seas End Spalding PE12 6LU
Proposal Erection of dwelling and garage

Name Sue Armour
Address Environmental Protection Officer South Holland District Council

Date Submitted 08-08-18
For/Against Comments

The Humberside Materials Laboratory Ltd report does not address the potential for buried asbestos containing materials (ACM) that was originally reported by a member of the public, and which is the reason that land contamination was originally considered at this location. Either further site investigation to address this is required, or alternatively a method statement from the contractor stating what would happen if suspected ACM was identified during site works is required.
If this is to be conditioned, please note that I cannot respond further until 20th August 2018.