## Buttery, Lucy

**From:** Buttery, Lucy
**Sent:** 22 April 2021 12:07
**To:** Buttery, Lucy
**Subject:** FW: Moulton Chapel- document review, and soil gas protection measures (H13-0858-20)

**From:** Matrix Planning Ltd <gordon@matrixplanning.co.uk>
**Sent:** 21 April 2021 14:56
**To:** Armour, Susan (SHBK) <Susan.Armour@breckland-sholland.gov.uk>
**Cc:** Buttery, Lucy <lbuttery@sholland.gov.uk>
**Subject:** RE: Moulton Chapel- document review, and soil gas protection measures (H13-0858-20)

Mimecast Attachment Protection has deemed this file to be safe, but always exercise caution when opening files.

**This message originated from outside your organization**

Dear Sue,

Thank you for your email.

- We confirm use of the Visqueen barrier.
- Doc 4 is attached
- We confirm that, as a minimum, we will provide 1st party verification with photos and delivery notes.

Regards

Gordon

Gordon Smith, MRTPI
Matrix Planning Ltd
07789 483 134

gordon@matrixplanning.co.uk
www.matrixplanning.co.uk

**From:** Armour, Susan <Susan.Armour@breckland-sholland.gov.uk>
**Sent:** 21 April 2021 14:37
**To:** Simon Weatherley <simon.weatherley@groundengineering.co.uk>; Matrix Planning Ltd <gordon@matrixplanning.co.uk>
**Cc:** Buttery, Lucy (SHDC) <lbuttery@sholland.gov.uk>
**Subject:** RE: Moulton Chapel- document review, and soil gas protection measures (H13-0858-20)

Thank you Simon.

Gordon,

If it is proposed to use the Visqueen Gas Barrier product, then I am happy with this.

Please can you resend document 4 (from your email of 12/4) with this product detailed.

Verification – Your previous document 6 refers to the NHBC requirements for verification, for us, the Local Authority, we accept 1st party verification, but expect to receive as a minimum photos and the delivery notes to site for the materials.

Once you have confirmed the above I will be in a position to recommend discharge of part ii of H13-0844-17 with part iii remaining outstanding.

Regards


Sue

**Sue Armour** | Environmental Protection Officer | **South Holland District Council**

Telephone : 01775 764738
**www.sholland.gov.uk**

*Please update my details in your contacts as my email address will be changing from 4th May 2021 to susan.armour@sholland.gov.uk. Thank you*

Please note my current working days are Monday to Thursday termtime, Monday and one other day in school holidays.




**From:** Simon Weatherley [mailto:simon.weatherley@groundengineering.co.uk]
**Sent:** 21 April 2021 13:15
**To:** Matrix Planning Ltd <gordon@matrixplanning.co.uk>; brent@postland.co.uk; Tom Clark <Tom@postland.co.uk>
**Cc:** Armour, Susan <Susan.Armour@breckland-sholland.gov.uk>; Buttery, Lucy (SHDC) <lbuttery@sholland.gov.uk>
**Subject:** RE: Moulton Chapel- document review, and soil gas protection measures (H13-0858-20)

**This message originated from outside your organization**

SW/C14951 Moulton Chapel 21st April 2021

Gordon/Sue

To try and provide clarity on this, Ground Engineering Limited have compared the gas regime to BS8485, CS2, for the whole development, which Sue is happy with.

Please see the Parsons report using Ground Engineering Limited gas results and providing recommendations based on the BS8485 CS2. Also attached is the proposed gas barrier specification, I do not know whether this membrane is acceptable.

Regards

Simon