
From: Grant, David
Sent: 28 November 2023 10:47
To: _planningadvice
Subject: FW: H13-0959-23 Moulton Bulb Company

Please add this email to the DIP under 6SUP – Additional surface water drainage info for SHIDB.

Many thanks,

Mr David Grant | Senior Planning Officer | **South Holland District Council**

Direct Dial: 01775 764472

www.sholland.gov.uk

Please note that any informal officer opinion expressed by this email is without prejudice and is not binding on the Council during the consideration of any formal application.



From: john cooper <c.a.d@btconnect.com>
Sent: 28 November 2023 10:42
To: Planning Department <planning@wlma.org.uk>
Cc: Grant, David <dgrant@sholland.gov.uk>
Subject: H13-0959-23 Moulton Bulb Company

Caution: This message originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe. If you believe it is suspicious please forward to Suspicious.Emails@pspsl.co.uk and delete the email.

F.A.O. Yvonne Smith

Good morning

I do apologise, the overall area of the building should indeed be 3088m² as per the Surface Water Drainage report Rec C. The figure shown on the block plan is the internal area, so not the total impermeable area. Hope that this clears up the query, we will be submitting an application under Byelaw 3 and Byelaw 10 in the near future.

Regards

John
Cooper Architectural Design