

Installation Type	Unit of Measure	Capacity/Flow rate (1)	Use Factor (2)	Fixed use (litres/person/day) (3)	Litres/person/day = [(1)x(2)] + (3) (4)
WC (single flush)	Flush Volume (litres)		4.42	0.00	0
WC (dual flush)	Full flush Volume (litres)	6	1.46	0.00	8.76
	Part flush Volume (litres)	4	2.96	0.00	11.84
WC (multiple fittings)	Average effective flushing Volume (litres)		4.42	0.00	0
Taps (excluding kitchen/utility room taps)	Flow rate (litres/min)	5.00	1.58	1.58	9.48
Bath (where shower also present)	Capacity to overflow(litres)	160.00	0.11	0.00	17.60
Shower (where bath also present)	Flow Rate(litres / minute)	7.50	4.37	0.00	32.78
Bath Only	Capacity to overflow(litres)		0.50	0.00	0
Shower Only	Flow Rate (litres/minute)		5.60	0.00	0
Kitchen/Utility room sink taps	Flow rate (litres/minute)	5.00	0.44	10.36	12.56
Washing Machine	(Litres/kg dry load)	8.17	2.1	0.00	17.16
Dishwasher	(Litres/place setting)	1.25	3.6	0.00	4.50
Waste disposal unit	(Litres/use)	☐ Present	3.08	0.00	0
Water Softener	(Litres/person/day)		1.00	0.00	0
	(5)	Total Calculated use (litres/person/day) =SUM(column 4)			114.68
	(6)	Contribution from greywater (litres/person/day)			0
	(7)	Contribution from rainwater (litres/person/day)			0
	(8)	Normalisation factor			0.91
	(9)	Total internal water consumption = [(5)-(6)-(7)]x(8) (litres/person/day)			104.36
	(10)	External water use			5.0
	(11)	Total water consumption (Building Regulation 17.K) =(9)+(10)(litres/person/day)			109.4

Installation Type	Make/Model (mandatory)	Litres/Person/Day
WC (dual flush)	Groche WC concealed cistern 6/4 Litre	20.6
Taps	Ideal Standard Tempo Basin Mixer Tap, with 5 Litre Regulator	9.48
Baths (shower(s) present)	160 Litre Bath	17.60
Showers (bath(s) present)	Ideakrain L1 300mm Rainshower with vertical arm	32.78
Kitchen Taps	x52 Low Kitchen Mono Mixer 5 Litre	12.56
Washing Machines	Standard	17.16
Dishwasher	Standard	4.50



©Water Research Centre Limited 2025

[Terms and Conditions](#)
[System Requirements](#)