Online Comment

Application	H13-0977-21
Location	Land North of Roman Road Moulton Chapel Spalding
Proposal	Details of scheme to deal with contamination, estate road & footways, surface water drainage & foul water drainage including connection points & discharge rates (Conditions 9, 15, 16 & 17 of H13-1215-18)

Name	Sue Armour
Address	Environmental Protection Officer SHDC
Date Submitted	13-10-21
For/Against	Objections

The submitted EPS limited report 'Ground Investigation Report Land off Roman Road, Moulton Chapel EPS Ref: UK18.4158 dated 26th October 2018 Issue 1' is a geotechnical report to provide information for foundation design. It is not a phase 1 desk study leading to the formulation of a conceptual site model.
I am therefore not in position to recommend discharge of condition 9 of H13-1215-18 at this time. I suggest that the applicant goes back to their consultant and commissions an appropriate report.