

## Online Comment

**Application** H13-1262-16  
**Location** Glebe Farm Roman Bank Saracens Head PE12 8BB  
**Proposal** Addition of 3 bays to existing cold store to create new bulk box store

---

**Name** Steve Branson  
**Address** Environmental Health Technician Safety and Environment

**Date Submitted** 03-03-17  
**For/Against** Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5 dB(A) when measured as a 15 minute LAeq at any residential boundary not within the applicant's ownership.