



Planning Application - Anglian Water Response

Anglian Water site reference:	PLN-0243329
Response date:	25 June 2026
Local Planning Authority:	South Holland District Council
Planning application reference:	H14-0065-26
Site address:	Land off Farnborough Close Pinchbeck Spalding PE11 5AF
Proposal description:	Erection of 40 dwellings, garages and associated infrastructure.

Should you wish to discuss this response, please find our contact details below:

Phone: 03450263912 (Monday to Friday 08:00 – 17:00 excluding bank holidays)

Email: planningliaison@anglianwater.co.uk

Response prepared by Anglian Water Growth, Planning and Capacity Team.

Please find our website below:

<https://www.anglianwater.co.uk/developing/planning--capacity/>

Section 1 - Assets Affected - Informative

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted:

Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore, the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

Section 2 - Wastewater Treatment - Condition

This site is within the catchment of Spalding Water Recycling Centre (WRC), which currently can accommodate the additional flows generated by the proposed development. Spalding WRC is included within our Business Plan as a named growth scheme with investment delivery planned between 2025-2030.

To ensure there is no pollution or deterioration in the receiving watercourse due to the additional foul flows that would arise from the development, we recommend a planning condition is applied if permission is granted:

Condition: Prior to occupation, written confirmation from Anglian Water must be submitted confirming there is sufficient headroom at the water recycling centre to accommodate the foul flows from the development site. This condition shall cease to have effect if the development is first occupied after April 2030.

Reason: to protect water quality, prevent pollution and secure sustainable development having regard to paragraphs 7/8 and 187 of the National Planning Policy Framework

Section 3 - Used Water Disposal

This response has been based on the following submitted documents:

FLOOD RISK ASSESSMENT REV 1 November 2025

Proposed Drainage Strategy drawing no. 0422-JCE-00-SI-SK-C-3000 REV P01 April 2026

Proposed Drainage Strategy drawing no. 0422-JCE-00-SI-SK-C-3001 REV P01 April 2026

The sewerage network at present has available capacity for the anticipated foul flows. Please note we are unable to make comments on private assets that are not adopted by Anglian Water. If the applicant is proposing to connect to Anglian Water foul sewer network via the privately owned sewers, the applicant will need to seek permission from the owners of these sewers to connect. If the developer wishes to connect to our sewerage network, they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection.

1. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087 Option 2.
2. INFORMATIVE - Protection of existing assets - When an Anglian Water asset is shown on record plans within the land identified for proposed development, it is recommended that the applicant contacts the Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers or assets will not be permitted (without agreement) from Anglian Water.
3. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory minimum easement width of 3 metres from a pipeline without agreement from Anglian Water. Easements are subject to specific easement requirements dependent on the size and depth of the sewer or asset, or any advice or comment provided by Anglian Water. Please contact our Development Services Team on 0345 606 6087 - Option 2 for any queries.
4. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 Option 2 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

From the FLOOD RISK ASSESSMENT REV 1 November 2025, Proposed Drainage Strategy drawing no. 0422-JCE-00-SI-SK-C-3000 REV P01 April 2026 and Proposed Drainage Strategy drawing no. 0422-JCE-00-SI-SK-C-3001 REV P01 April 2026 submitted to support the planning application. The proposed method of surface water management is via piped system which discharges into a basin. The basin then discharges into an IDB Drain. Please note we are unable to make comments on surface water private assets. The proposed surface water strategy does not relate to Anglian Water operated assets. As such, we are unable to provide comments on the suitability of the surface water management. The Local Planning Authority should seek the advice of the Lead Local Flood Authority or the Internal Drainage Board. The Environment Agency should be consulted if the drainage system directly or indirectly involves the discharge of water into a watercourse.

If planning permission is granted, the strategy should be listed within the decision notice with any approved plans.

Should the proposed method of surface water management change to include interaction with Anglian Water operated assets, we would wish to be re-consulted to ensure that an effective surface water drainage strategy is prepared and implemented