

Online Comment

Application H14-0328-20
Location Herdgate Lane Pinchbeck Spalding PE11 3UP
Proposal Erection of cold store - retrospective

Name Steve Branson
Address South Holland District Council Priory Road

Date Submitted 26-05-20
For/Against Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.