

Online Comment

Application H14-0355-17
Location Keston Nurseries Mill Green Road Pinchbeck PE11 3PU
Proposal Proposed residential development (re-submission of H14-0942-16)

Name J Reith
Address Environmental Health Technician Safety and Environment

Date Submitted 18-05-17
For/Against Comments

The Site Investigation Report by Ground Engineering Reference C13895 dated August 2016 states that in relation to soil contamination 'testing was not done in the operational northern part of the site associated with the glasshouses'. It also refers to fuel storage tanks and associated pipework which will also require testing and validation after removal. As further information is required for the site I request parts 2 - 4 of the contaminated land condition.