

Online Comment

Application H14-0450-22
Location Adj. 47 Milestone Lane Pinchbeck Spalding
Proposal Residential Development - Erection of Dwelling (re-submission of H14-0811-21)

Name Sue Armour
Address Environmental Protection Officer SHDC

Date Submitted 30-05-22
For/Against Comments

I request that either:

a) i) Prior to the commencement of any development details of precautionary ground gas protection measures shall be submitted to and approved in writing by the Local Planning Authority.

ii) Prior to the first occupation, a suitably detailed ground gas verification report shall be submitted and approved in writing by the Local Planning Authority.

OR

The standard land contamination conditions be applied at this location.