
From: Joshua Frost (LFR) <Joshua.Frost@lincolnshire.gov.uk>
Sent: 18 June 2026 16:13
To: James Bramma; _planningadvice
Subject: Re: Objection to planning application H14-0455-26 - Brylaine Travel Ltd

CAUTION: This message originated from outside of your organisation. **DO NOT** click links or open attachments unless you recognise the sender and know the content is safe. If you believe it is suspicious please report with the phish alert button.

This message needs your attention

- Some Recipients have never replied to this person.

Powered by Mimecast

Good afternoon, James.

Also, for the attention of Planning Officer Jacob Bryan

Thank you for your email, James.

The river was considered as part of the original consultation but due to the distance from the nearest space of hardstanding it was deemed unsuitable for fire operations. Therefore, my objection will stand on the grounds of requiring the installation of a fire hydrant.

I have copied in the planning authority in order to maintain their involvement and awareness of this consultation.

Kind Regards

Josh Frost BA(Hons)
Fire Safety Supervisor
Lincolnshire Fire and Rescue



From: James Bramma
Sent: Wednesday, June 17, 2026 14:23
To: LFR Fire Safety
Subject: Re: Objection to planning application H14-0455-26 - Brylaine Travel Ltd

You don't often get email from info@brammadesign.co.uk. [Learn why this is important](#)

Caution external: This email originated from outside of the council. Do not click on links or open attachments unless you are confident the email is legitimate

Dear sir/madam

I am emailing with reference to your recent objection to the above application.

In terms of the new fire hydrant request...we respectfully ask, would it be possible for an appliance to pump water from the river in the event of a fire as it's in such close proximity?
If this is the case, perhaps you could remove the objection on that basis.

A copy of the objection is attached for your perusal

Many thanks

Kind regards

James

James Brama

JB Architectural Design Services

M: 07837 735718 T: 01775 820416

W: brammadesign.co.uk