Online Comment

Application	H14-0461-18
Location	W Hargrave & Son Ltd 53-55 Knight Street Pinchbeck PE11 3RA
Proposal	Proposed single storey freezer/store room to rear of existing premises

---

Name	Steve Branson
Address	SHDC Priory Road

Date Submitted	21-05-18
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.