Online Comment

Application	H14-0485-23
Location	Land off Glenside North Pinchbeck Spalding
Proposal	Details of surface water disposal, landscaping, tree planting and proposed boundary treatments. (Conditions 4, 5 and 6 of H14-0449-22)

Name	Black Sluice Internal Drainage Board
Address	Station Road Swineshead Boston PE20 3PW

Date Submitted	05-06-23
For/Against	Comments

Black Sluice IDB District.

Whilst the applicant has indicated that crate soakaways are to be used, the applicant has also indicated "subject to percolation test".
Until such details are provided, the Board believes this condition can not be satisfied.