

Asher, Marie

From: Buttery, Lucy
Sent: 05 July 2021 15:31
To: _planningadvice
Subject: Planning application ref. H14-0533-21 - Spalding Lifestyle and Garden Centre

H14-0533-21 – 2LFR

Lucy Buttery BA (Hons), MA, MRTPI | Principal Planning Officer | **South Holland District Council**

DDI: 01775 764470 |

www.sholland.gov.uk



From: Peter Kontowski <Peter.Kontowski@lincoln.fire-uk.org>
Sent: 05 July 2021 11:44
To: Buttery, Lucy <lbuttery@sholland.gov.uk>
Cc: Risk Management (LFR) <Risk.Management@lincoln.fire-uk.org>
Subject: RE: Planning application ref. H14-0533-21 - Spalding Lifestyle and Garden Centre

This message originated from outside your organization

Good morning,

I can confirm the submitted details are acceptable. Although I didn't receive a consultation email for the above condition compliance application, this has already been addressed in conjunction with Anglian Water Services and a fire hydrant incorporated into the water mains scheme as indicated on the associated drawing number NMC0075947 / 10590946 which is included with the planning documents,

Kind regards,

Peter
Peter Kontowski | Technical Support Manager
Operational Support | Lincolnshire Fire and Rescue
Fire and Police Headquarters, Deepdale Lane, Lincoln, LN2 2LT
Tel: 01522 554 903 | **Mob:** 07765 897 337



www.lincolnshire.gov.uk/lfr

CONFIDENTIALITY STATEMENT

Disclaimer: This email and any files transmitted with it are confidential and solely for the use of the individual or entity to whom they are addressed. Therefore if the reader of this message is not the intended recipient, you are hereby notified that any dissemination, distribution or copying of this email is strictly prohibited. Any views or opinions expressed are those of the author and do not necessarily represent the views of Lincolnshire Fire and Rescue unless otherwise explicitly stated. The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information is legally exempt from disclosure, the confidentiality of this email and your reply cannot be guaranteed.