

Online Comment

Application H15-0321-20
Location PROVIDENCE HOUSE NORTH DROVE QUADRING FEN PE11 4QS
Proposal Proposed storage building for boxed potatoes and external plant room building

Name Steve Branson
Address South Holland District Council Priory Road

Date Submitted 12-05-20
For/Against Comments

No objection but would wish to attach the following condition:
Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.