Online Comment

Application	H16-0002-16
Location	37A NEW ROAD SPALDING PE11 1DW
Proposal	Proposed change of use of ground floor from Class A1 (Retail) to Class A5 (takeaway)

Name	Steve Branson
Address	Environmental Health Technician Safety and Environment
Date Submitted	02-02-16
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.