Online Comment

Application	H16-0020-17
Location	M J L Skipmaster Ltd Bourne Road Pode Hole PE11 3LL
Proposal	Proposed detached shot blasting shed

Name	Noise and Contaminated Land
Address	Environmental Health Technician Safety and Environment
Date Submitted	02-03-17
For/Against	Comments

No objection but would wish to attach the following conditions:

All shot blasting to be carried out inside the building with doors closed.

Noise from fixed plant and machinery not exceed the background noise level by more than 5dB(A) when measured as a 15 minute LAeq at any residential boundary not within the applicant's ownership.