

Ms A Brown
Stowe Farm
Stowe
Langtoft
Peterborough
PE6 9SF

Council Offices
Priory Road
Spalding
Lincolnshire
PE11 2XE
Admin 01775 764723
DC Officers 01775 764703
facsimile 01775 762937
planningadvice@sholland.gov.uk
www.sholland.gov.uk

TOWN AND COUNTRY PLANNING ACT 1990

FULL

Reference: H16-0029-20 **Date of Decision:** 17th April 2020
Applicant: Ms A Brown
Stowe Farm
Stowe
Langtoft
Peterborough
PE6 9SF
Location: Rear Of 175 Hawthorn Bank Spalding Lincs
Description: Erection of detached house - re-submission of H16-0856-19

South Holland District Council hereby give notice that this application has been GRANTED (or equivalent) subject to the following condition(s):

- 1 The development must be begun not later than the expiration of three years beginning with the date of this permission.

Reason: As required by Section 91 of the Town and Country Planning Act 1990 as amended by the Planning and Compulsory Purchase Act 2004.

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans:
PH105-1
PH105-2
PH105-3
Block Plan (1:500)
Flood Risk Assessment (Prepared by S M Hemmings - Dated 5th June 2019)
PH105-4
Site Location Plan (1:1250)
Application Form

Reason: For the avoidance of doubt and in the interests of proper planning.

- 3 The development hereby permitted shall be carried out in accordance with the measures set out in the Flood Risk Assessment (Prepared by S M Hemmings - Dated 5th June 2019) forming part of this planning application, in particular the following measures shall be fully implemented before the property is first occupied:

-Finished floor levels shall be set at 3.60 metres above Ordnance Datum (AOD).

-Flood resistant and resilient techniques shall be used up to 300mm above the ground floor level of the new building.

Reason: To ensure that the development does not increase the risk of flooding or be at risk of flooding.

This Condition is imposed in accordance with Policies 3 and 4 of the South East Lincolnshire Local Plan, 2019 and national guidance contained in Section 14 of the National Planning Policy Framework, 2019.

- 4 Details of the design and positions of all external boxes for gas and electricity supplies and of any gas flues and soil vent pipes shall be submitted to and approved in writing by the Local Planning Authority prior to their installation and there shall be no variation from the details so approved.

Reason: To ensure that the Local Planning Authority retains control over these details of the development in the interests of the character and appearance of the development and the visual amenity of the area in which it is set.

This Condition is imposed in accordance with Policies 2 and 3 of the South East Lincolnshire Local Plan, 2019.

- 5 The development hereby permitted shall not be commenced until a scheme to deal with any contamination of land or pollution of controlled waters has been submitted to and approved in writing by the Local Planning Authority (LPA) and until the measures approved in that scheme have been implemented. The scheme shall include all of the following measures:

i) a desk-top study carried out to identify and evaluate all potential sources of contamination and the impacts on land and/or controlled waters, relevant to the site. The desk-top study shall establish a 'conceptual site model' and identify all plausible pollutant linkages. Furthermore, the assessment shall set objectives for intrusive site investigation works/Quantitative Risk Assessment (or state if none required). Two full copies of the desk-top study and a non-technical summary shall be submitted to the LPA without delay upon completion.

ii) if identified as being required following the completion of the desk-top study, a site investigation shall be carried out to fully and effectively characterise the nature and extent of any land contamination and/or pollution of controlled waters. It shall specifically include a risk assessment that adopts the Source-Pathway-Receptor principle, in order that any potential risks are adequately assessed taking into account the sites existing status and proposed new use. Two full copies of the site investigation and findings shall be forwarded to the LPA without delay upon completion.

iii) thereafter, a written method statement detailing the remediation requirements for land

contamination and/or pollution of controlled waters affecting the site shall be submitted to and approved in writing by the LPA, and all requirements shall be implemented and completed to the satisfaction of the LPA. No deviation shall be made from this scheme. If during redevelopment contamination not previously considered is identified, then the LPA shall be notified immediately and no further work shall be carried out until a method statement detailing a scheme for dealing with the suspect contamination has been submitted to and agreed in writing by the LPA.

iv) two full copies of a full closure report shall be submitted to and approved in writing by the LPA. The report shall provide verification that the required works regarding contamination have been carried out in accordance with the approved Method Statement(s). Post-remediation sampling and monitoring results shall be included in the closure report to demonstrate that the required remediation has been fully met.

Note

The applicant is advised that the phased risk assessment required by the Contaminated Land Scheme Condition should be carried out in accordance with the procedural guidance of the Environmental Protection Act 1990 Part 11A.

The applicant's attention is also drawn to the document entitled "Developing Land Within Lincolnshire - A guide to submitting planning applications to develop land that may be contaminated", which can be obtained through the Local Environmental Health Department.

Reason: To assess whether the site is polluted and to address any pollution to ensure a satisfactory development. This issue is integral to the development and therefore full details need to be finalised prior to the commencement of works.

This Condition is imposed in accordance with Policy 30 of the South East Lincolnshire Local Plan, 2019.

- 6 The water consumption of the dwelling hereby permitted should not exceed the requirement of 110 litres per person per day (as set out as the optional requirement in Part G of the Building Regulations 2010 and the South East Lincolnshire Local Plan, 2019). The person carrying out the work must inform the Building Control Body that this duty applies. A notice confirming the requirement for the water consumption has been met shall be submitted to the Building Control Body and Local Planning Authority, no later than five days after the completion of the dwelling.

Reason: To protect the quality and quantity of water resources available to the district.

This Condition is imposed in accordance with Policy 31 of the South East Lincolnshire Local Plan, 2019.

- 7 The horse chestnut trees and pine tree marked on Drawing No. PH105-4 to be retained, shall not be cut down, up-rooted, destroyed, topped or lopped unless first agreed in writing by the Local Planning Authority. Should any of the trees die or authorisation be given for their removal, they shall be replaced within six months thereafter with a tree of such size and species which shall first be agreed in writing by the Local Planning Authority, such a tree will continue to assume the protection afforded to the original under this condition.

Reason: To ensure the protection of existing trees on the site, in the interests of the visual amenity of the locality.

This Condition is imposed in accordance with Policies 2 and 3 of the South East

Lincolnshire Local Plan, 2019 and national guidance contained in Section 15 of the National Planning Policy Framework, 2019.

- 8 The horse chestnut trees and pine tree marked on Drawing No. PH105-to be retained shall be protected during construction work as follows:

i) Before commencement of any development, chestnut paling or similar fencing 1.5 metres in height shall be provided around the perimeter of the Root Protection Area as calculated in British Standard 5837:2012, of all trees to be retained.

No materials, equipment, site huts, fuels or other items shall be placed or stored within the areas enclosed by the fencing so erected and the ground levels within those areas shall not be altered, nor shall any excavation be made nor any fires lit.

ii) Before commencement of any development, details of the means of construction, drainage and surfacing of the access drive, including a method statement for the protection of the existing trees shall be submitted to and approved in writing by the Local Planning Authority. The access drive shall be completed in its entirety in accordance with the approved details before the dwelling is occupied.

Note: It is advised that a 'no dig' method should be used where roadways / driveways / paths are likely to be in the Root Protection Areas. Construction should take note of the Arboricultural Advisory and Information Service publication: APN 12 Driveways Close to Trees. Tarmacadam is not an appropriate material to site near the base of trees. A cellular confinement system filled with gravel or other permeable filling is required.

iii) Where access is essential in close proximity to the retained trees and is likely to cause soil compaction, temporary ground protection should be used.

iv) The soil levels should not be altered around the base of the retained trees.

Note: An increase in soil level around the base of a tree can make conditions adjacent to the trunk damp and suitable for fungal growth; it can also increase the distance for water / gaseous exchange to the tree's roots, which can be detrimental to the health of the tree.

Reason: In the interest of preserving existing trees on site and the character of the surrounding area.

This Condition is imposed in accordance with Section 15 of the National Planning Policy Framework (2019)

- 9 Before the commencement of the development hereby permitted beyond oversight, the approval of the Local Planning Authority is required to a scheme of landscaping and tree planting for the site indicating, inter alia, the number, species, heights on planting and positions of all the trees, together with details of post-planting maintenance. Such scheme as is approved by the Local Planning Authority shall be carried out and completed in its entirety during the first planting season following practical completion of the development. All trees, shrubs and bushes shall be maintained by the owner or owners of the land on which they are situated for the period of five years beginning with the date of completion of the scheme and during that period all losses shall be made good as and when necessary.

Note: The applicant is recommended to employ a qualified and experienced landscape designer to produce a landscaping scheme for the development.

Reason: To ensure that the development is adequately landscaped, in the interests of its visual amenity and that of the area in which it is set.

This Condition is imposed in accordance with Policies 2 and 3 of the South East Lincolnshire Local Plan, 2019.

Notes:

The Local Planning Authority has acted positively and proactively in determining this application by assessing it against all material considerations, including national guidance, planning policies and representations that have been received during the public consultation exercise, and subsequently determining to grant planning permission.

This decision notice, the relevant accompanying report and the determined plans can be viewed online at <http://planning.sholland.gov.uk/OcellaWeb/planningSearch>

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works.



Phil Norman
Planning and Building Control Manager
South Holland District Council

BUILDING REGULATIONS:

This decision refers only to planning permission as granted under the Town and Country Planning Act 1990. The works that you are proposing may also require Building Regulations and this planning permission does not give authority under Building Regulations to commence work. Please contact the Building Control section for further information on 01775 764557 or bcadmin@sholland.gov.uk

RIGHTS OF APPEAL

Appeals to the Secretary of State

If you are aggrieved by the decision of your Local Planning Authority to refuse permission for the proposed development or grant consent subject to conditions, then you can appeal to the Secretary of State under Section 78 of the Town and Country Planning Act 1990 or Section 20 of the Planning (Listed Building and Conservation Areas) Act 1990.

Timescales for appealing

The deadlines for appeals are calculated from the **date of decision** and are as follows for the types of applications below:

12 Weeks	6 Months	8 Weeks
Householder Applications	Planning Permission	Consent to Display Adverts
Minor Commercial Development	Listed Building Consent	
Agricultural Determinations	Other Prior Approval Applications	
Householder Prior Approval Applications		

If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal. Further details are on GOV.UK.

Enforcement Notices

If an enforcement notice was served prior to the planning application being determined then the deadline for appealing is 28 days from the date of the **planning refusal**.

If an enforcement notice is served after the planning application is determined then the deadline for appealing is 28 days from the date of the **enforcement notice** OR **the timescales stated above for each application type** from the date of the planning refusal - whichever is sooner.

Appeals can be made online at: <https://www.gov.uk/planning-inspectorate>. If you are unable to access the online appeal form, please contact the Planning Inspectorate to obtain a paper copy of the appeal form on tel: 0303 444 5000.

The Secretary of State can allow a longer period for giving notice of an appeal but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to the Secretary of State that the

Local Planning Authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under the order.

Purchase Notices

If either the Local Planning Authority or the Secretary of State refuses permission to develop land or grant it subject to conditions the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor can he render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances the owner may serve a purchase notice on the Council in whose area the land is situated. This notice will require the Council to purchase his interest in the land in accordance with the provisions of the Part VI of the Town and Country Planning Act 1990 or Section 32 of the Planning (Listed Building and Conservation Areas) Act 1990.

Compensation

In certain circumstances compensation may be claimed from the Local Planning Authority if permission is refused or granted subject to conditions by the Secretary of State on appeal or on reference of the application to him.

These circumstances are set out in Section 114 and related provisions of the Town and Country Planning Act 1990 and Section 27 of the Planning (Listed Building and Conservation Areas) Act 1990.