

W&D SUPPORT
28 FEB 2012
POSTROOM
KE

Welland & Deepings
Internal Drainage Board
Deeping House
Welland Terrace
Spalding
PE11 2TD

Chief Executive - Mrs Karen Daft

Engineer To The Board - Stan Pywell

Our Ref. SWP/MPC/P/S/14

COMMENTS

This matter is being
handled by
Stan Pywell

Your Ref. H16-0134-2

27th February 2012

FAO: Mr Richard Fidler
South Holland District Council
Council Offices
Priory Road
Spalding
Lincs
PE11 2XE

Dear Mr Fidler


Re: Taylor Wimpey East Midlands Ltd, Wygate Park South, Spalding, Lincs
Details of Surface Water Disposal

The proposed details for the culverting of the northern ditch, as shown on drawing numbered TWY014/113/A, is acceptable to the Board.

Surface water from the site may be discharged unattenuated subject to receiving the Board's consent under The Land Drainage Act 1991. The consent will be conditional on payment of a development contribution.

The Board will not be adopting any on site systems.

Yours sincerely



Engineer to the Board

cc. Mark Dinsdale, Taylor Wimpey East Midlands Ltd., The Osiers Business Park, Laversall Way, Leicester, LE19 1DX