

ALL ADOPTABLE HIGHWAY WORKS MUST BE IN ACCORDANCE WITH LINCOLNSHIRE COUNTY COUNCIL SPECIFICATION FOR ADOPTABLE HIGHWAYS (2011)

Suitable arisings from excavations provide useful engineering material for raising levels and in forming and contouring areas of landscaping. Accordingly, the finished surface levels on this development have been designed to incorporate the benefit of this material, either derived on this site or other TWUK developments

ALL ADOPTABLE DRAINAGE WORKS MUST BE IN ACCORDANCE WITH WRC "SEWERS FOR ADOPTION" 6TH EDITION (MARCH 2006)

Catchpit
manhole
1500Ø

Catchpit
manhole
1500Ø

Catchpit
manhole
1500Ø

Catchpit
manhole
1500Ø

FUTURE DEVELOPMENT
BY OTHERS

NOTES

- The contractor shall check all tie-ins for line and level with existing before commencing any works. The Engineer shall be notified immediately, in writing, should any errors be found.
 - Any discrepancies, of whatever nature, must be reported to the Engineer prior to the commencement or continuance of any further works.
 - It is the responsibility of the contractor to execute the works at all times in strict accordance with the requirements of the Health and Safety at Work Act 1974, and CDM Regulations 2007. The Contractor will be deemed to have allowed for full compliance, including full liaison with the CDM Coordinator, within his rates.
 - All private drainage works to be in accordance with the requirements of Building Regulations 2000, Part H, "Drainage and waste disposal", (1st April 2002).
 - All pipes to be bedded and backfilled in accordance with Part H, Diagram 10. Shallow pipes shall be protected in accordance with Part H, Diagram 11.
 - Unless otherwise stated, all private drainage to be 100mm diameter. Gradients have been shown where there are pipe capacity issues and these should be regarded as minimums. Unless there are constraints dictating otherwise, gradients shall generally be 1 in 80. 100mm diameter pipes shall not be laid flatter than 1 in 80, 150mm diameter pipes shall not be laid flatter than 1 in 150.
 - All pipes, chambers and fittings to be installed strictly in accordance with the manufacturers instructions.
 - Pipes which run adjacent to buildings shall be installed in strict accordance with Part H, Diagram 8.
 - All manholes and inspection chambers situated in areas subject to vehicular loading to have class B125 covers and frames to BS EN124 and those not subject to vehicular loading to have class A15 covers and frames.
 - All drains in the vicinity of existing or proposed trees to be constructed in accordance with the requirements of NHBC Practice Note 3.
 - Private drainage frames must be tied to manhole risers by use of manufacturers ties (e.g. Polypipe ref. FRK500 fixing kit and FRK501 black ties). The ground works contractor will be held fully responsible for any accidents due to incorrect fitting or failure to use the correct manufacturers fixing equipment.
 - All existing land drains encountered on site during construction to be re-connected.
 - Should any departure from the slab level be considered, agreement shall be sought from the Engineer immediately and prior to commencement or continuance of any works, and should take full account of all restrictions to the slab level.
 - Garage slabs relate to the finished level of the concrete at the front entrance of the garage.
 - Where a drive slopes towards a garage there is to be a 75mm ramp up to the garage slab.
 - Maximum gradients of gardens to be 1 in 6 (unless stated otherwise), except for designed banking works.
 - All dimensions in metres unless otherwise stated.
- Flow Route Notes**
- Flow routes are required to facilitate the potential route of flood flow in rainfall events exceeding the storm sewer design criteria as required by Sewers For Adoption 6th Edition and PPS25.
 - Flow routes illustrated on the drawings shall be kept clear of permanent physical obstructions which may impede the flow of surface water (i.e. walls, retaining walls). Failure to do this will increase the risk of flooding to properties.
 - House slab levels, external works, drive and garden gradients have been designed in such a way as to minimise the risk of flooding to properties immediately adjacent to flow routes. The Engineer shall be consulted in the event of any changes to the design in order to assess the impact on flood risk.

Architects layout shown is based upon TWY014 - 01 (latest revision).
This layout may be subject to change and is intended for indicative purposes only.

TENDER

ADOPTABLE DRAINAGE LEGEND

- Existing foul water sewer
- Existing surface water sewer
- Proposed foul water sewer (to be adopted)
- Proposed surface water sewer (to be adopted)
- Proposed trapped road gully (150mm outlet)

PRIVATE DRAINAGE LEGEND

- Proposed foul water drain
- Proposed surface water drain
- Proposed inspection chamber (traditional)
- Proposed preformed inspection chamber (depth 0.9m/1.2m or less)
- Proposed preformed inspection chamber (depth 600mm or less)
- Proposed shallow access chamber (normally preformed 225mm or 250mm dia)
- Proposed rodding eye
- Proposed chamber invert level
- Proposed yard gully in drives (150Ø outlet to larger parking areas)
- Proposed drainage channel
- Proposed slab level
- Target levels to car parks
- LEGEND
- Exposed Brickwork below DPC (eg. 4C = 4 courses)
- Part M access point
- Slab on edge retaining feature (Max. height 0.60m)
- Structural Retaining Wall (Example shows max. height of 1.2m)
- Refer to George Wimpey East Midlands Standard Details
- Banking works (Indicates banks between 1:3 to 1:6)
- Site boundary
- Adoptable street lighting column

For lateral manholes sizing should be as follows,

- For depth less than 1m from top of pipe to ground, the chambers internal dimensions shall be 900mm long and 675mm wide. Chamber constructed using rectangular concrete sections or in Class B engineering brick.
- Between 1.0-1.5m from top of pipe to ground, the chambers internal dimensions shall be 1040mm long and 675mm wide. Chamber constructed using rectangular concrete sections or in Class B engineering bricks
- For depth greater than 1.5m from top of pipe to ground, the chambers internal dimensions shall be a minimum of 1200mm diameter. The chamber shall be constructed using pre cast constructed rings

Rev No.	Revision	Date	Drawn By	Checked By

Written dimensions to be taken. Do not scale off the drawings.

Any discrepancies, written or scaled, should be brought to the attention of the engineer immediately.

This drawing to be read in conjunction with the relevant Bills of Materials and Local Authority Specification.

CDM NOTE: The design has been undertaken as far as possible to avoid risks to health and safety or to reduce and control the effects of any unavoidable risks.

All relevant information identifying the unavoidable risks has been passed to the planning supervisor for inclusion in the Health & Safety plan.

The Health & Safety plan will be issued by the planning supervisor with these drawings.

Wormald Burrows Partnership
Civil Engineering Consultants
12a - 18a Hulton Street, Highgate, Leicestershire, LE1 1AA
Tel: (01767) 312344 Fax: (01767) 315434
Web: www.wbpartnership.com
Email: engineer@wbpartnership.com

Project:
Proposed Development at Wygate Park, Spalding, Lincolnshire

Drawing Description:
Private Drainage and External Works Layout Sheet 3 of 3

Client:
Taylor Wimpey East Midlands Ltd
Unit 2, The Orlers Business Park
Loversall Way, Leicester
LE19 1DX

Drawing Number:
TWY014/108

Drawn By:
AMZ
Date:
13.10.11

Checked By:
WVD
Date:
11.11.11

WBP Drawing Number:
E2236/9

Scale:
1:200 @ A1