Online Comment

Application	H16-0197-24
Location	MILLFIELD HOUSE SPALDING COMMON SPALDING PE11 3AU
Proposal	Details of contamination and pollution (Condition 4 of H16-0134-23)

Name	Sue Armour
Address	Team Leader Environmental Protection SHDC
Date Submitted	26-04-24
For/Against	Comments

I have reviewed the GeoDyne Ltd report 'Millfield House, Spalding Common, Spalding Environmental Assessment' Project no. D44007 dated 20/2/2024 and am in general agreement with the conclusions. I therefore recommend discharge of condition 4 parts i & ii of H16-0134-23, with part iii and condition 5 remaining outstanding.
The applicant proposes to install ground gas protection measures to CS2 in lieu of undertaking any ground gas monitoring and as per their adjacent development. The details of the proposed installation and proposed validation should be submitted to discharge 4iii.